

தமிழ்நாடு தீயணைப்பு மற்றும் மீட்பு பணிகள் துறை
தடையின்மைச் சான்று
தேனாம்பேட்டை தீயணைப்பு-மீட்பு பணிகள் நிலையம்

ந.க.எண்: 319/V/ தேனா/2020

நாள் : 05.12.2020

எண்: 17/2020

பொருள் : தீயணைப்பு-மீட்பு பணித்துறை , தேனாம்பேட்டை தீயணைப்பு-மீட்பு பணிகள் நிலையம் - பள்ளிக்கூடம் நிறுவ / நிறுவப்பட்டுள்ள பள்ளிக்கூடத்திற்கு அங்கீகாரம் வழங்கிட தடையின்மை சான்று வழங்குதல்-குறித்து.

- பார்வை :** 1. அரசு ஆணை எண் : 122, பள்ளிக்கல்வி (x 2) துறை, நாள் : 14.09.2004
 2. அரசு ஆணை எண் : 123, பள்ளிக்கல்வி (x 2) துறை, நாள் : 14.09.2004
 3. அரசு ஆணை(நிலை) எண் : 206, பள்ளிக்கல்வி (தொ.க.2 (2) துறை, நாள்: 22.12.2015
 4. THE CORRESPONDENT
 என்பவரிடமிருந்து 01.12.2020 அன்று பெறப்பட்ட விண்ணப்பம்

பார்வையில் காணும் அரசு ஆணை மற்றும் விண்ணப்பத்தின்படி கதவு இலக்கம் எண்: 228, AVVAI SHUNMUGAM ROAD, CHENNAI-600 086 என்ற முகவரியில் நிறுவப்பட்டுள்ள M/S.NATIONAL PUBLIC SCHOOL என்ற பள்ளியினை 04.12.2020 அன்று நிலைய அலுவலர் திரு.மா.வெள்ளைச்சாமி என்பவரால் ஆய்வு செய்யப்பட்டது இவ்விடத்தில் பள்ளிக்கூடத்திற்கு அங்கீகாரம் வழங்கிட கீழ்க்காணும் நிபந்தனைகளுக்கு உட்பட்டு (05.12.2020 முதல் 04.12.2021) தீயணைப்பு-மீட்புப்பணி நோக்கிலிருந்து யாதொரு தடையும் இல்லை.

CONDITIONS

1. This License is valid for One Year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. **Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.**
 - (a). Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2005.
 - (b). The Staircase treads and flooring shall be treated with rough finish (grooving) to avoid Falling of children.
 - (c). As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class room shall have to be limited to 45 students.
 - (d). Periodical maintenance and care should be taken to maintain all fire protection equipments.

B. Sujatha
Ms. B. Sujatha, M.Sc., B.Ed
 Principal
 National Public School
 Gopalapuram, Chennai-86

- (e). Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City South District at Teynampet.
- (f). The classrooms should always be in the ground floor up to 3rd standards.
- (g). The classroom Doors / Windows Should be Made of Either Non-Combustible Material or Materials with High Fire Resistance Rating.
- (h). The classroom Doors / Windows Shall always open outwards.
- (i). The classroom Doors / Windows Shutters opened should not obstruct movement along the exit or escape route.
- (j). The Classroom Shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch/ tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
- (k). The School shall have proper Evacuation of plan of action to rescue the children during any emergency in the school premises.

If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled



Let. *[Signature]*
05.12.2020
நிலைய அலுவலர்
தீயணைப்பு (ம) மீட்புபணிகள் துறை
தேனாம்பேட்டை நிலையம்
சென்னை - 600 006.

பெறுநர் : **The Correspondent,**
National Public School,
No: 228, Avvai Shunmugam Road,
Chennai - 600 086.

நகல் : மாவட்ட அலுவலர் , தென்சென்னை மாவட்டம்.

[Signature]
Ms. B. Sujatha, M.Sc., B.Ed
Principal
National Public School
Gopalapuram, Chennai-86